



PLAN ON GUIDES



PLAN AT HEAD



SECTION

DESIGN NOTES!
 The structure supporting the shutter must be a fire - resistant separating element (to BS 476: Part 20,21,22:1987) having a fire resistance greater or equal to that required of the shutter. The structure must also be capable of supporting the shutter for the required fire resistance period without compromising the fire performance of the shutter.

AVON INDUSTRIAL DOORS LTD	TITLE:	DRAWN:	DRG. No.
	2 HOUR SELF COIL / FUSIBLE LINK FIRE SHUTTER	D.J.J.	AV 1002
		DATE:	
		05 / 03 / 2007	